

Shackelford Elementary School Water Test Results

Sample ID	Location code	Location description	Collection Date	Lead ug/L
BE99143	SHACKELFORD_ELEMENTARY	Room 15 - Sink Faucet	4/12/2019	9.4
BE99144	SHACKELFORD_ELEMENTARY	Cafeteria Kitchen - West Faucet	4/12/2019	ND
BE99145	SHACKELFORD_ELEMENTARY	Room K8 - Sink Faucet	4/12/2019	28
BE99146	SHACKELFORD_ELEMENTARY	Room 29 - East Faucet	4/12/2019	5
BE99147	SHACKELFORD_ELEMENTARY	Room 31 - West Faucet	4/12/2019	ND

The EPA recommends lead levels to be at 15 parts per billion (ppb) or below.

ND = Non-detect (lead was not detected)